



# WPDES PERMIT

*STATE OF WISCONSIN*  
*DEPARTMENT OF NATURAL RESOURCES*  
**PERMIT TO DISCHARGE UNDER THE WISCONSIN POLLUTANT DISCHARGE  
ELIMINATION SYSTEM**

**VILLAGE OF TONY**

is permitted, under the authority of Chapter 283, Wisconsin Statutes, to discharge from a facility  
located at

**SW 1/4, SECTION 33, T35N-R5W, TOWN OF DEWEY, SOUTH OF TONY, WISCONSIN**  
to

**AN EFFLUENT DITCH TO A WETLAND INTO A TRIBUTARY TO DEER TAIL CREEK WITHIN THE  
DEER TAIL WATERSHED IN THE UPPER CHIPPEWA RIVER BASIN IN RUSK COUNTY**

in accordance with the effluent limitations, monitoring requirements and other conditions set  
forth in this permit.

The permittee shall not discharge after the date of expiration. If the permittee wishes to continue to discharge after this expiration date an application shall be filed for reissuance of this permit, according to Chapter NR 200, Wis. Adm. Code, at least 180 days prior to the expiration date given below.

State of Wisconsin Department of Natural Resources  
For the Secretary

By \_\_\_\_\_  
Michelle BalkLudwig  
Wastewater Field Supervisor

\_\_\_\_\_  
Date Permit Signed/Issued

**PERMIT TERM: EFFECTIVE DATE - April 01, 2024**

**EXPIRATION DATE - March 31, 2029**

## TABLE OF CONTENTS

<b>1 INFLUENT REQUIREMENTS</b>	<b>1</b>
1.1 SAMPLING POINT(S)	1
1.2 MONITORING REQUIREMENTS	1
1.2.1 <i>Sampling Point 701 - INFLUENT TO PLANT</i>	1
<b>2 SURFACE WATER REQUIREMENTS</b>	<b>2</b>
2.1 SAMPLING POINT(S)	2
2.2 MONITORING REQUIREMENTS AND EFFLUENT LIMITATIONS	2
2.2.1 <i>Sampling Point (Outfall) 001 - EFFLUENT DISCHARGE</i>	2
<b>3 LAND APPLICATION REQUIREMENTS</b>	<b>9</b>
3.1 SAMPLING POINT(S)	9
3.2 MONITORING REQUIREMENTS AND LIMITATIONS	9
3.2.1 <i>Sampling Point (Outfall) 003 - LAGOON SLUDGE</i>	9
<b>4 SCHEDULES</b>	<b>15</b>
4.1 PFOS/PFOA MINIMIZATION PLAN DETERMINATION OF NEED	15
4.2 EFFLUENT LIMITATIONS FOR BOD5 AND TOTAL SUSPENDED SOLIDS	15
4.3 WATER QUALITY BASED EFFLUENT LIMITS (WQBELS) FOR TOTAL PHOSPHORUS	16
4.4 SLUDGE MANAGEMENT PLAN	18
<b>5 STANDARD REQUIREMENTS</b>	<b>19</b>
5.1 REPORTING AND MONITORING REQUIREMENTS	19
5.1.1 <i>Monitoring Results</i>	19
5.1.2 <i>Sampling and Testing Procedures</i>	19
5.1.3 <i>Recording of Results</i>	19
5.1.4 <i>Reporting of Monitoring Results</i>	19
5.1.5 <i>Compliance Maintenance Annual Reports</i>	20
5.1.6 <i>Records Retention</i>	20
5.1.7 <i>Other Information</i>	20
5.1.8 <i>Reporting Requirements – Alterations or Additions</i>	20
5.2 SYSTEM OPERATING REQUIREMENTS	21
5.2.1 <i>Noncompliance Reporting</i>	21
5.2.2 <i>Flow Meters</i>	21
5.2.3 <i>Raw Grit and Screenings</i>	21
5.2.4 <i>Sludge Management</i>	21
5.2.5 <i>Prohibited Wastes</i>	22
5.2.6 <i>Bypass</i>	22
5.2.7 <i>Scheduled Bypass</i>	22
5.2.8 <i>Controlled Diversions</i>	22
5.2.9 <i>Proper Operation and Maintenance</i>	23
5.2.10 <i>Operator Certification</i>	23
5.3 SEWAGE COLLECTION SYSTEMS	23
5.3.1 <i>Sanitary Sewage Overflows and Sewage Treatment Facility Overflows</i>	23
5.3.2 <i>Capacity, Management, Operation and Maintenance (CMOM) Program</i>	25
5.3.3 <i>Sewer Cleaning Debris and Materials</i>	25
5.4 SURFACE WATER REQUIREMENTS	25
5.4.1 <i>Permittee-Determined Limit of Quantitation Incorporated into this Permit</i>	25
5.4.2 <i>Appropriate Formulas for Effluent Calculations</i>	26
5.4.3 <i>Visible Foam or Floating Solids</i>	26
5.4.4 <i>Surface Water Uses and Criteria</i>	26
5.4.5 <i>Percent Removal</i>	26
5.4.6 <i>PFOS and PFOA Requirements</i>	27

5.5 LAND APPLICATION REQUIREMENTS	27
5.5.1 Sludge Management Program Standards And Requirements Based Upon Federally Promulgated Regulations	27
5.5.2 General Sludge Management Information	27
5.5.3 Sludge Samples	27
5.5.4 Land Application Characteristic Report	27
5.5.5 Calculation of Water Extractable Phosphorus	27
5.5.6 Annual Land Application Report	27
5.5.7 Other Methods of Disposal or Distribution Report	28
5.5.8 Approval to Land Apply	28
5.5.9 Soil Analysis Requirements	28
5.5.10 Land Application Site Evaluation	28
<b>6 SUMMARY OF REPORTS DUE</b>	<b>29</b>

# 1 Influent Requirements

## 1.1 Sampling Point(s)

Sampling Point Designation	
Sampling Point Number	Sampling Point Location, WasteType/Sample Contents and Treatment Description (as applicable)
701	Representative samples shall be collected in the influent sample building before the first pond.

## 1.2 Monitoring Requirements

The permittee shall comply with the following monitoring requirements.

### 1.2.1 Sampling Point 701 - INFLUENT TO PLANT

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Flow Rate		MGD	Daily	Total Daily	
BOD <sub>5</sub> , Total		mg/L	Weekly	24-Hr Flow Prop Comp	
Suspended Solids, Total		mg/L	Weekly	24-Hr Flow Prop Comp	

## 2 Surface Water Requirements

### 2.1 Sampling Point(s)

Sampling Point Designation	
Sampling Point Number	Sampling Point Location, WasteType/Sample Contents and Treatment Description (as applicable)
001	Representative samples shall be collected after the V-notch weir on the effluent discharge line prior to discharge to the ditch draining to a wetland tributary to Deer Tail Creek.

### 2.2 Monitoring Requirements and Effluent Limitations

The permittee shall comply with the following monitoring requirements and limitations.

#### 2.2.1 Sampling Point (Outfall) 001 - EFFLUENT DISCHARGE

Monitoring Requirements and Effluent Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Flow Rate		MGD	Daily	Total Daily	
BOD <sub>5</sub> , Total	Weekly Avg	45 mg/L	Weekly	Grab	INTERIM LIMIT effective April, May, September, October and November until August 31, 2028 when the final limit goes into effect per the "Effluent Limitations for BOD <sub>5</sub> and Total Suspended Solids" schedule.
BOD <sub>5</sub> , Total	Weekly Avg	30 mg/L	Weekly	Grab	Limit effective December, January, February, March, June, July and August until September 1, 2028 when this limit becomes effective year round. See the "Effluent Limitations for BOD <sub>5</sub> and Total Suspended Solids" schedule for more information.

<b>Monitoring Requirements and Effluent Limitations</b>					
<b>Parameter</b>	<b>Limit Type</b>	<b>Limit and Units</b>	<b>Sample Frequency</b>	<b>Sample Type</b>	<b>Notes</b>
BOD <sub>5</sub> , Total	Monthly Avg	30 mg/L	Weekly	Grab	INTERIM LIMIT effective April, May, September, October and November until August 31, 2028 when the final limit goes into effect per the "Effluent Limitations for BOD <sub>5</sub> and Total Suspended Solids" schedule.
BOD <sub>5</sub> , Total	Monthly Avg	20 mg/L	Weekly	Grab	Limit effective December, January, February, March, June, July and August until September 1, 2028 when this limit becomes effective year round. See the "Effluent Limitations for BOD <sub>5</sub> and Total Suspended Solids" schedule for more information.
Suspended Solids, Total	Weekly Avg	45 mg/L	Weekly	Grab	INTERIM LIMIT effective April, May, September, October and November until August 31, 2028 when the final limit goes into effect per the "Effluent Limitations for BOD <sub>5</sub> and Total Suspended Solids" schedule.
Suspended Solids, Total	Weekly Avg	30 mg/L	Weekly	Grab	Limit effective December, January, February, March, June, July and August until September 1, 2028 when this limit becomes effective year round. See the "Effluent Limitations for BOD <sub>5</sub> and Total Suspended Solids" schedule for more information.
Suspended Solids, Total	Monthly Avg	30 mg/L	Weekly	Grab	INTERIM LIMIT effective April, May, September, October and November until August 31, 2028 when the final limit goes into effect per the "Effluent Limitations for BOD <sub>5</sub> and Total Suspended Solids" schedule.

Monitoring Requirements and Effluent Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Suspended Solids, Total	Monthly Avg	20 mg/L	Weekly	Grab	"Limit effective December, January, February, March, June, July and August until September 1, 2028 when this limit becomes effective year round. See the "Effluent Limitations for BOD <sub>5</sub> and Total Suspended Solids" schedule for more information.
pH Field	Daily Max	9.0 su	Weekly	Grab	
pH Field	Daily Min	6.0 su	Weekly	Grab	
Dissolved Oxygen	Daily Min	4.0 mg/L	Weekly	Grab	
Nitrogen, Ammonia (NH <sub>3</sub> -N) Total	Weekly Avg	21 mg/L	Weekly	Grab	Limit is effective in April.
Nitrogen, Ammonia (NH <sub>3</sub> -N) Total	Weekly Avg	14 mg/L	Weekly	Grab	Limit is effective in May.
Nitrogen, Ammonia (NH <sub>3</sub> -N) Total	Monthly Avg	13 mg/L	Weekly	Grab	Limit is effective in April.
Nitrogen, Ammonia (NH <sub>3</sub> -N) Total	Monthly Avg	5.5 mg/L	Weekly	Grab	Limit is effective in May.
Nitrogen, Ammonia (NH <sub>3</sub> -N) Total	Daily Max - Variable	mg/L	Weekly	Grab	Enter the daily ammonia result on the eDMR and compare to the Nitrogen, Ammonia Variable Limit column to determine compliance.
Nitrogen, Ammonia Variable Limit		mg/L	Weekly	Calculated	Using the daily pH result look up the applicable ammonia limit in the "Ammonia Limitation" section and report the variable limit on the eDMR.
Phosphorus, Total	Monthly Avg	5.0 mg/L	Weekly	Grab	INTERIM LIMIT - Limit is in effect until required actions in the "Phosphorus" schedule are completed.
E. coli		#/100 ml	Weekly	Grab	Monitoring is effective May through September during periods of discharge. See the "E. coli Monitoring" section for more information.

<b>Monitoring Requirements and Effluent Limitations</b>					
<b>Parameter</b>	<b>Limit Type</b>	<b>Limit and Units</b>	<b>Sample Frequency</b>	<b>Sample Type</b>	<b>Notes</b>
PFOS		ng/L	See Permit Note	Grab	Monitoring only. See "PFOS/PFOA" sections and "PFOS/PFOA Minimization Plan Determination of Need" schedule for more information.
PFOA		ng/L	See Permit Note	Grab	Monitoring only. See "PFOS/PFOA" sections and "PFOS/PFOA Minimization Plan Determination of Need" schedule for more information.
Nitrogen, Total Kjeldahl		mg/L	Annual	Grab	See the "Nitrogen Series Monitoring" section for more information.
Nitrogen, Nitrite + Nitrate Total		mg/L	Annual	Grab	See the "Nitrogen Series Monitoring" section for more information.
Nitrogen, Total		mg/L	Annual	Calculated	Total Nitrogen = Total Nitrogen Kjeldahl (mg/L) + Nitrite + Nitrate Nitrogen (mg/L). See the "Nitrogen Series Monitoring" section for more information.

### 2.2.1.1 Annual Average Design Flow

The annual average design flow of the permittee's wastewater treatment facility is 0.0226 MGD.

### 2.2.1.1 Notification of Discharges

Your assigned department Wastewater Engineer shall be notified at least 7 days prior to an anticipated discharge. The pond contents shall be sampled prior to any discharge to assure adequate stabilization has taken place.

### 2.2.1.2 Ammonia Limitation

Daily maximum ammonia limits vary based on effluent pH values. Total ammonia (NH<sub>3</sub>-N) sampling shall coincide with pH samples. Record the applicable variable ammonia limit from the table below on the Electronic Discharge Monitoring Report (eDMR) in the 'Nitrogen, Ammonia Variable Limit' column. Report the effluent ammonia sample result in the 'Nitrogen, Ammonia (NH<sub>3</sub>-N) Total' column. Compare the variable daily maximum ammonia limit to the reported ammonia result, record the number of exceedances in the box to the right of the 'Limit in Effect' 'Daily Max' row in the 'Summary' tables at the end of the eDMR.

Note: pH values should be rounded to the nearest 0.1 s.u. before using the table below. For example, if the pH field reading is 8.04, the value of 8.0 should be used.

**Ammonia Variable Limits Table**  
*Daily maximum ammonia limits based on Effluent pH*



Effluent pH s.u.	Limit mg/L	Effluent pH s.u.	Limit mg/L	Effluent pH s.u.	Limit mg/L
6.0 ≤ pH ≤ 6.1	83	7.0 < pH ≤ 7.1	51	8.0 < pH ≤ 8.1	11
6.1 < pH ≤ 6.2	82	7.1 < pH ≤ 7.2	46	8.1 < pH ≤ 8.2	8.8
6.2 < pH ≤ 6.3	80	7.2 < pH ≤ 7.3	40	8.2 < pH ≤ 8.3	7.3
6.3 < pH ≤ 6.4	78	7.3 < pH ≤ 7.4	35	8.3 < pH ≤ 8.4	6.0
6.4 < pH ≤ 6.5	75	7.4 < pH ≤ 7.5	31	8.4 < pH ≤ 8.5	5.0
6.5 < pH ≤ 6.6	72	7.5 < pH ≤ 7.6	26	8.5 < pH ≤ 8.6	4.1
6.6 < pH ≤ 6.7	69	7.6 < pH ≤ 7.7	22	8.6 < pH ≤ 8.7	3.4
6.7 < pH ≤ 6.8	65	7.7 < pH ≤ 7.8	19	8.7 < pH ≤ 8.8	2.8
6.8 < pH ≤ 6.9	60	7.8 < pH ≤ 7.9	16	8.8 < pH ≤ 8.9	2.4
6.9 < pH ≤ 7.0	56	7.9 < pH ≤ 8.0	13	8.9 < pH ≤ 9.0	2.0

### 2.2.1.3 E. coli Monitoring

Weekly *E. coli* bacteria samples from the months of a disinfection season (May through September) are needed to determine if a future limit is needed. Weekly monitoring in May, June, July, August and September during periods of discharge is required. Once data is captured for a month, that respective month through the remaining permit term does not need to be sampled again.

### 2.2.1.4 Phosphorus Water Quality-Based Effluent Limitation(s)

The final water quality based effluent limit (WQBEL) for phosphorus is 0.23 mg/L monthly average, 0.075 mg/L six-month average, and 0.085 lbs/day six-month average and will take effect on the date specified in the Compliance Schedule unless:

- (A) As part of the application for the next reissuance, or prior to filing the application, the permittee submits either: 1.) An application for water quality trading; or 2.) An application for a variance; or 3.) New information or additional data that supports a recalculation of the numeric limitation; and
- (B) The Department modifies, revokes and reissues, or reissues the permit to incorporate a revised limitation before the effective date of the phosphorus WQBEL.

If Water Quality Trading is approved as part of the permit application for the next reissuance or as part of an application for a modification or revocation and reissuance, the plan and specifications submittal, construction, and final effective dates for compliance with the total phosphorus WQBEL may change in the reissued or modified permit. In addition, the numeric value of the WQBEL may change based on new information (e.g. a TMDL) or additional data. If a variance is approved for the next reissuance, interim limits and conditions will be imposed in the reissued permit in accordance with ss. 283.15 or 283.16, Stats., and applicable regulations. A permittee may apply for a variance to the phosphorus WQBEL at the next reissuance even if the permittee did not apply for a phosphorus variance as part of this permit reissuance.

Any increase in the limit is subject to s. NR 102.05(1) and ch. NR 207, Wis. Adm. Code. When a six-month average effluent limit is specified for Total Phosphorus the applicable averaging periods are May through October and November through April.

### 2.2.1.5 Alternative Approaches to Phosphorus WQBEL Compliance

Rather than upgrading its wastewater treatment facility to comply with WQBELs for total phosphorus, the permittee may use Water Quality Trading to achieve compliance under ch. NR 217, Wis. Adm. Code, provided that the permit is modified, revoked and reissued, or reissued to incorporate any such alternative approach. The permittee may also implement an upgrade to its wastewater treatment facility in combination with Water Quality Trading to achieve

compliance, provided that the permit is modified, revoked and reissued, or reissued to incorporate any such alternative approach. If the Final Compliance Alternatives Plan concludes that a variance will be pursued, the Plan shall provide information regarding the basis for the variance.

#### **2.2.1.6 Submittal of Permit Application for Next Reissuance and Pollutant Trading Plan or Variance Application**

The permittee shall submit the permit application for the next reissuance at least 6 months prior to expiration of this permit. If the permittee intends to pursue pollutant trading to achieve compliance, the permittee shall submit an application for water quality trading with the application for the next reissuance. If system upgrades will be used in combination with pollutant trading to achieve compliance with the final water quality-based limit, the reissued permit will specify a schedule for the necessary upgrades. If the permittee intends to seek a variance, the permittee shall submit an application for a variance with the application for the next reissuance.

#### **2.2.1.7 PFOS/PFOA Sampling and Reporting Requirements**

For grab samples, as defined per s. NR 218.04(10), Wis. Adm. Code, a single sample at a location as defined by the sample point description shall be taken during the time of the day most representative to capture all potential discharges. If extra equipment besides the sample bottle is used to collect the sample, it is recommended that a one-time equipment blank is collected with the first sample. An equipment blank would be collected by passing laboratory-verified PFAS-free water over or through field sampling equipment before the collection of a grab sample to evaluate potential contamination from the equipment used during sample.

If any equipment blanks are performed, these results shall be reported in the comments section of the eDMR and shall be documented in the reports submitted as part of the PFOS/PFOA Minimization Plan Determination of Need schedule of the permit.

Monitoring is required weekly during periods of discharge up to a maximum of six samples per year.

#### **2.2.1.8 PFOS/PFOA Minimization Plan Determination of Need**

The permittee shall monitor PFOS and PFOA as specified in the table above and report on the effluent concentrations including trends in monthly and annual average PFOS and PFOA concentrations as specified in the PFOS/PFOA Minimization Plan Determination of Need Schedule.

If, after reviewing the data, the Department determines that a minimization plan for PFOS and PFOA is necessary based on the procedures in s. NR 106.98(4), Wis. Adm. Code, the Department will notify the permittee in writing that a PFOS and PFOA minimization plan that satisfies the requirements in s. NR 106.99, Wis. Adm. Code, is required.

The permittee shall submit an initial plan for Department approval no later than 90 days after written notification was sent from the Department in accordance with s. NR 106.985(2)(a), Wis. Adm. Code. Pursuant to s. NR 106.985(2)(b), Wis. Adm. Code, as soon as possible after Department approval of the PFOS and PFOA minimization plan, the Department will modify or revoke and reissue the permit in accordance with public notice procedures under ch. 283, Wis. Stats., and ch. NR 203, Wis. Adm. Code, to include the PFOS and PFOA minimization plan and other related terms and condition.

If, however, the Department determines that a PFOS and PFOA minimization plan is unnecessary based on the procedures in s. NR 106.98(4), Wis. Adm. Code, the Department shall notify the permittee that no further action is required. Per s. NR 106.98(3)(a), Wis. Adm. Code, the Department may reduce monitoring frequency to once every 3 months (quarterly) on a case-by-case basis, but only after at least 12 representative results have been generated. If the permittee requests a reduction in monitoring and the Department agrees a reduction would be appropriate, the permit may be modified in accordance with public notice procedures under ch. 283, Wis. Stats., and ch. NR 203, Wis. Adm. Code, to incorporate this change.

#### **2.2.1.9 Nitrogen Series Monitoring**

Monitoring for Total Kjeldahl Nitrogen (TKN), Nitrite + Nitrate Nitrogen, and Total Nitrogen shall be conducted once each year during a period of discharge.

**Testing:** It is preferable that the annual samples occur in rotating seasons. Monitoring shall be performed during normal operating conditions. Permittees are not allowed to turn off or otherwise modify treatment systems, production processes, or change other operating or treatment conditions during testing.

### 3 Land Application Requirements

#### 3.1 Sampling Point(s)

The discharge(s) shall be limited to land application of the waste type(s) designated for the listed sampling point(s) on Department approved land spreading sites or by hauling to another facility.

Sampling Point Designation	
Sampling Point Number	Sampling Point Location, WasteType/Sample Contents and Treatment Description (as applicable)
003	Representative samples shall be collected from the accumulated sludge from the primary pond at various locations and depths that are composited for analysis.

#### 3.2 Monitoring Requirements and Limitations

The permittee shall comply with the following monitoring requirements and limitations.

##### 3.2.1 Sampling Point (Outfall) 003 - LAGOON SLUDGE

**Sludge Management:** The permittee shall contact the Department prior to recycling/disposing of any sludge. The permittee shall monitor for the following parameters during the second year of the permit, (2025). Analysis shall be submitted by **January 31, 2026**.

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Solids, Total		Percent	Once	Composite	
Arsenic Dry Wt	Ceiling	75 mg/kg	Once	Composite	
Arsenic Dry Wt	High Quality	41 mg/kg	Once	Composite	
Cadmium Dry Wt	Ceiling	85 mg/kg	Once	Composite	
Cadmium Dry Wt	High Quality	39 mg/kg	Once	Composite	
Copper Dry Wt	Ceiling	4,300 mg/kg	Once	Composite	
Copper Dry Wt	High Quality	1,500 mg/kg	Once	Composite	
Lead Dry Wt	Ceiling	840 mg/kg	Once	Composite	
Lead Dry Wt	High Quality	300 mg/kg	Once	Composite	
Mercury Dry Wt	Ceiling	57 mg/kg	Once	Composite	
Mercury Dry Wt	High Quality	17 mg/kg	Once	Composite	
Molybdenum Dry Wt	Ceiling	75 mg/kg	Once	Composite	
Nickel Dry Wt	Ceiling	420 mg/kg	Once	Composite	
Nickel Dry Wt	High Quality	420 mg/kg	Once	Composite	
Selenium Dry Wt	Ceiling	100 mg/kg	Once	Composite	
Selenium Dry Wt	High Quality	100 mg/kg	Once	Composite	
Zinc Dry Wt	Ceiling	7,500 mg/kg	Once	Composite	
Zinc Dry Wt	High Quality	2,800 mg/kg	Once	Composite	
Nitrogen, Total Kjeldahl		Percent	Per Application	Composite	
Nitrogen, Ammonia (NH <sub>3</sub> -N) Total		Percent	Per Application	Composite	

<b>Monitoring Requirements and Limitations</b>					
<b>Parameter</b>	<b>Limit Type</b>	<b>Limit and Units</b>	<b>Sample Frequency</b>	<b>Sample Type</b>	<b>Notes</b>
Phosphorus, Total		Percent	Per Application	Composite	
Phosphorus, Water Extractable		% of Tot P	Per Application	Composite	
Potassium, Total Recoverable		Percent	Per Application	Composite	
PFOA + PFOS		µg/kg	Once	Calculated	Report the sum of PFOA and PFOS. See PFAS Permit Sections for more information.
PFAS Dry Wt			Once	Grab	Perfluoroalkyl and Polyfluoroalkyl Substances based on updated DNR PFAS List. See PFAS Permit Sections for more information.

<b>Other Sludge Requirements</b>	
<b>Sludge Requirements</b>	<b>Sample Frequency</b>
<b>List 3 Requirements – Pathogen Control:</b> The requirements in List 3 shall be met prior to land application of sludge.	<b>Required only when sludge is land applied</b>
<b>List 4 Requirements – Vector Attraction Reduction:</b> The vector attraction reduction shall be satisfied prior to, or at the time of land application as specified in List 4.	<b>Required only when sludge is land applied</b>

### 3.2.1.1 Requirements for Potential and/or Unscheduled Land Application of Sludge

Monitoring for List 1 and PFAS shall occur in year two of permit term (2025) unless a sludge removal date has been established which would occur within the permit term, but in a different year. Monitoring for List 2 is highly recommended during the same sampling event to determine acreage needs for land application of sludge should it be necessary at a future date.

If a sludge removal date has been established other than in year two (2025), monitoring for Lists 1, 2, 3 & 4, PCBs and PFAS shall occur in the year of, but prior to, land application of the removed sludge. Monitoring must be done, and compliance assured, prior to land application, in addition to all other requirements specified herein and in ch. NR 204, Wis. Adm. Code. The permittee shall notify the Department prior to such land application. If sludge removal and land application are necessary after the monitoring for List 1 and PFAS (if listed) in year two of the permit, monitoring for Lists 2, 3 & 4 and PCBs shall be done in the year of and prior to land application.

### 3.2.1.2 Changes in Feed Sludge Characteristics

If a change in feed sludge characteristics, treatment process, or operational procedures occurs which may result in a significant shift in sludge characteristics, the permittee shall reanalyze the sludge for List 1, 2, 3 and 4 parameters each time such change occurs.

**3.2.1.3 Sludge Which Exceeds the High Quality Limit**

Cumulative pollutant loading records shall be kept for all bulk land application of sludge which does not meet the high quality limit for any parameter. This requirement applies for the entire calendar year in which any exceedance of Table 3 of s. NR 204.07(5)(c), is experienced. Such loading records shall be kept for all List 1 parameters for each site land applied in that calendar year. The formula to be used for calculating cumulative loading is as follows:

$$[(\text{Pollutant concentration (mg/kg)} \times \text{dry tons applied/ac}) \div 500] + \text{previous loading (lbs/acre)} = \text{cumulative lbs pollutant per acre}$$

When a site reaches 90% of the allowable cumulative loading for any metal established in Table 2 of s. NR 204.07(5)(b), the Department shall be so notified through letter or in the comment section of the annual land application report (3400-55).

**3.2.1.4 Lists 1, 2, 3, and 4**

<b>List 1 TOTAL SOLIDS AND METALS</b>
See the Monitoring Requirements and Limitations table above for monitoring frequency and limitations for the List 1 parameters
Solids, Total (percent)
Arsenic, mg/kg (dry weight)
Cadmium, mg/kg (dry weight)
Copper, mg/kg (dry weight)
Lead, mg/kg (dry weight)
Mercury, mg/kg (dry weight)
Molybdenum, mg/kg (dry weight)
Nickel, mg/kg (dry weight)
Selenium, mg/kg (dry weight)
Zinc, mg/kg (dry weight)

<b>List 2 NUTRIENTS</b>
See the Monitoring Requirements and Limitations table above for monitoring frequency for the List 2 parameters
Solids, Total (percent)
Nitrogen Total Kjeldahl (percent)
Nitrogen Ammonium (NH <sub>4</sub> -N) Total (percent)
Phosphorus Total as P (percent)
Phosphorus, Water Extractable (as percent of Total P)
Potassium Total Recoverable (percent)

<b>List 3</b>		
<b>PATHOGEN CONTROL FOR CLASS B SLUDGE</b>		
The permittee shall implement pathogen control as listed in List 3. The Department shall be notified of the pathogen control utilized and shall be notified when the permittee decides to utilize alternative pathogen control.		
The following requirements shall be met prior to land application of sludge.		
Parameter	Unit	Limit
Fecal Coliform*	MPN/gTS or CFU/gTS	2,000,000
<b>OR, ONE OF THE FOLLOWING PROCESS OPTIONS</b>		
Aerobic Digestion	Air Drying	
Anaerobic Digestion	Composting	
Alkaline Stabilization	PSRP Equivalent Process	
* The Fecal Coliform limit shall be reported as the geometric mean of 7 discrete samples on a dry weight basis.		

<b>List 4</b>		
<b>VECTOR ATTRACTION REDUCTION</b>		
The permittee shall implement any one of the vector attraction reduction options specified in List 4. The Department shall be notified of the option utilized and shall be notified when the permittee decides to utilize an alternative option.		
One of the following shall be satisfied prior to, or at the time of land application as specified in List 4.		
Option	Limit	Where/When it Shall be Met
Volatile Solids Reduction	≥38%	Across the process
Specific Oxygen Uptake Rate	≤1.5 mg O <sub>2</sub> /hr/g TS	On aerobic stabilized sludge
Anaerobic bench-scale test	<17 % VS reduction	On anaerobic digested sludge
Aerobic bench-scale test	<15 % VS reduction	On aerobic digested sludge
Aerobic Process	>14 days, Temp >40°C and Avg. Temp > 45°C	On composted sludge
pH adjustment	>12 S.U. (for 2 hours) and >11.5 (for an additional 22 hours)	During the process
Drying without primary solids	>75 % TS	When applied or bagged
Drying with primary solids	>90 % TS	When applied or bagged
Equivalent Process	Approved by the Department	Varies with process
Injection	-	When applied
Incorporation	-	Within 6 hours of application

### 3.2.1.5 Sludge Monitoring for PFAS

Sampling shall occur for perfluoroalkyl and polyfluoroalkyl compounds (PFAS) listed in the table below and as indicated in sampling point sections above. Monitoring shall occur at each sample point when sludge is generated regardless of the end use (i.e. land applied, hauled to another facility, landfilled).

<b>PERFLUOROALKYLCARBOXYLIC Acids (PFCAs)</b>	
PFBA	Perfluorobutanoic acid
PFPeA	Perfluroropentanoic acid
PFHxA	Perfluorohexanoic acid
PFHpA	Perfluoroheptanoic acid

PFOA	Perfluorooctanoic acid
PFNA	Perfluorononanoic acid
PFDA	Perfluorodecanoic acid
PFUnA	Perfluroundecanoic acid
PFDoA	Perfluorododecanoic acid
PFTriA	Perfluorotridecanoic acid
PFTeDA	Perfluorotetradecanoic acid
<b>PERFLUOROALKYLSULFONIC Acids (PFSAs)</b>	
PFBS	Perfluorobutane sulfonic acid
PFPeS	Perfluroropentane sulfonic acid
PFHxS	Perfluorohexane sulfonic acid
PFHpS	Perfluoroheptane sulfonic acid
PFOS	Perfluorooctane sulfonic acid
PFNS	Perfluorononane sulfonic acid
PFDS	Perfluorodecane sulfonic acid
PFDoS	Perfluorododecane sulfonic acid
<b>TELOMER SULFONIC Acids</b>	
4:2 FTSA	4:2 fluorotelomersulfonic acid
6:2 FTSA	6:2 fluorotelomersulfonic acid
8:2 FTSA	8:2 fluorotelomersulfonic acid
<b>PERFLUOROCTANCESULFONAMIDES (FOSAs)</b>	
PFOSA	Perflurorooctane sulfonamide
N-MeFOSA	N-Methyl perfluoroocatane sulfonamide
N-EtFOSA	N-Ethyl perfluorooctane sulfonamide
<b>PERFLUOROCTANCESULFONAMIDOACETIC Acids</b>	
N-MeFOSAA	N-Methyl perfluoroocatane sulfonamidoacetic acid
N-EtFOSAA	N-Ethyl perfluorooctane sulfonamidoacetic acid
<b>NATIVE PERFLUOROCTANCESULFONAMIDOETHANOLS (FOSEs)</b>	
N-MeFOSE	N-Methyl perfluorooctane sulfonamidoethanol
N-EtFOSE	N-Ethyl perfluorooctane sulfonamidoethanol
<b>PERFLUOROALKYLETHERCARBOXYLIC Acids (PFECAs)</b>	
HFPO-DA	Hexafluoropropylene oxide dimer acid
DONA	4,8-dioxa-3H-perfluorononanoic acid
<b>CHLORO-PERFLUOROALKYLSULFONATE</b>	
F-53B Major	9-chloroehexadecafluoro-3-oxanone-1-sulfonic acid
F-53B Minor	11-chloroelcosafluoro-3-oxaundecane-1-sulfonic acid

Note: If WDNR Lab Certification removes a particular compound from the reporting list above and upon receiving written communication from the department, reporting for that compound is no longer required.

### 3.2.1.6 Sampling and Reporting Sludge Samples for PFAS

Representative sludge samples shall be collected at each sample point as listed. At minimum, liquid sludge storage/digesters should be thoroughly mixed prior to sampling. Cake sludge samples should consist of seven equal



size discrete samples and be collected from different areas and depths then composited into one sample for laboratory analysis.

Note: If additional equipment is used for collecting sludge samples (i.e., shovels, compositing buckets, bottles, etc.), then a one-time equipment blank is recommended to be collected with the first sample. An equipment blank sample is collected by passing laboratory verified PFAS-free water over or through field sampling equipment before the collection of a representative sludge sample. The equipment blank result shall be reported on the annual Sludge Characteristics Form (3400-049) in the comment section when reporting PFAS concentrations in the sludge.

The permittee shall report each of the PFAS sludge monitoring results on the annual Sludge Characteristics and Monitoring Form (3400-049) as provided by the department. The permittee shall also report the summation of PFOS and PFOA on this same form. All results shall be reported in dry weight. The annual Sludge Characteristics and Monitoring Form (3400-049) are due January 31, of the year following the collection of the sludge samples.

The laboratory performing the analysis on any samples shall be certified for the applicable PFAS compounds in the solids matrix by the Wisconsin Laboratory Certification Program established under s. 299.11, Wis. Stats., and in accordance with s. NR 149.41, Wis. Adm. Code. If the EPA Office of Water publishes a 1600 series isotope dilution method for the analysis of PFAS in solids, the department recommends the use of the EPA method. The department may reject any sample results if results are produced by a laboratory that is not in compliance with certification requirements under ch. NR 149, Wis. Adm. Code.

### **3.2.1.7 PFAS Land Application Requirements**

The department recommends the landspreading and/or land application of sludge be done in a manner consistent with the most recent version of the “Interim Strategy for Land Application of Biosolids and Industrial Sludges containing PFAS”.

## 4 Schedules

### 4.1 PFOS/PFOA Minimization Plan Determination of Need

Required Action	Due Date
<p><b>Report on Effluent Discharge:</b> Submit a report on effluent PFOS and PFOA concentrations and include an analysis of trends in monthly and annual average PFOS and PFOA concentrations. This analysis should also include a comparison to the applicable narrative standard in s. NR 102.04(8)(d), Wis. Adm. Code.</p> <p>This report shall include all additional PFOS and PFOA data that may be collected including any influent, intake, in-plant, collection system sampling, and blank sample results.</p>	03/31/2025
<p><b>Report on Effluent Discharge and Evaluation of Need:</b> Submit a final report on effluent PFOS and PFOA concentrations and include an analysis of trends in monthly and annual average PFOS and PFOA concentrations of data collected over the last 24 months. The report shall also provide a comparison on the likelihood of the facility needing to develop a PFOS/PFOA minimization plan.</p> <p>This report shall include all additional PFOS and PFOA data that may be collected including any influent, intake, in-plant, collection system sampling, and blank sample results.</p> <p>The permittee shall also submit a request to the department to evaluate the need for a PFOS/PFOA minimization plan.</p> <p>If the Department determines a PFOS/PFOA minimization plan is needed based on a reasonable potential evaluation, the permittee will be required to develop a minimization plan for Department approval no later than 90 days after written notification was sent from the Department. The Department will modify or revoke and reissue the permit to include PFOS/PFOA minimization plan reporting requirements along with a schedule of compliance to meet WQBELs. Effluent monitoring of PFOS and PFOA shall continue as specified in the permit until the modified permit is issued.</p> <p>If, however, the Department determines there is no reasonable potential for the facility to discharge PFOS or PFOA above the narrative standard in s. NR 102.04(8)(d), Wis. Adm. Code, no further action is required and effluent monitoring of PFOS and PFOA shall continue as specified in the permit.</p>	03/31/2026

### 4.2 Effluent Limitations for BOD5 and Total Suspended Solids

The permittee shall comply with surface water limitations for BOD5 and Total Suspended Solids as specified. If a submittal is required, a timely submittal fulfills the notification.

Required Action	Due Date
<p><b>Operational Evaluation Report:</b> The permittee shall prepare and submit an Operational Evaluation Report to the Department for review and approval. The report shall include an evaluation of collected effluent data and proposed operational improvements that will optimize efficacy of the treatment plan to the extent possible enabling compliance with the final BOD5 and Total Suspended Solids limitations. The report shall include a plan and schedule for implementation of the operational improvements. These improvements shall occur as soon as possible. The report shall state whether the operational improvements are expected to result in compliance with the final BOD5 and Total Suspended Solids limitations.</p> <p>If the Operational Evaluation Report concludes that the operational improvements are expected to</p>	03/31/2025

<p>result in compliance with the final BOD5 and Total Suspended Solids limitations, the permittee shall comply with the final limitations by March 31, 2026 and the permittee is not required to comply with subsequent milestones identified below in this compliance schedule ('Submit Facility Plan', 'Final Plans and Specifications', 'Treatment Plant Upgrade to Meet Limitations', 'Construction Upgrade Progress Report', 'Complete Construction', 'Achieve Compliance').</p> <p>FACILITY PLAN - If the Operational Evaluation Report concludes that operational improvements alone are not expected to result in compliance with the final BOD5 and Total Suspended Solid limitations, the permittee shall initiate development of a facility plan for meeting final limitations and comply with the remaining required actions in this schedule of compliance.</p>	
<p><b>Submit Facility Plan:</b> If the Operational Evaluation Report concluded that the permittee cannot achieve final BOD5 and Total Suspended Solids limitations with operational improvements alone, the permittee shall submit a Facility Plan per s. NR 110.09, Wis. Adm. Code. The permittee may submit an abbreviated facility plan if the Department determines that the modifications are minor.</p>	03/31/2026
<p><b>Final Plans and Specifications:</b> The permittee shall submit final construction plans to the Department for approval pursuant to ch. NR 108, Wis. Adm. Code, specifying treatment plant upgrades that must be constructed to achieve compliance with final BOD5 and Total Suspended Solids limitations and a schedule for completing construction of the upgrades by the complete construction date specified below.</p>	03/31/2027
<p><b>Treatment Plant Upgrade to Meet Limitations:</b> The permittee shall initiate bidding, procurement, and/or construction of the project. The permittee shall obtain approval of the final construction plans and schedule from the Department pursuant to s. 281.41, Stats., prior to initiating activities defined as construction under ch. NR 108, Wis. Adm. Code. Upon approval of the final construction plans and schedule by the Department pursuant to s. 281.41, Stats., the permittee shall construct the treatment plant upgrades in accordance with the approved plans and specifications.</p>	03/31/2028
<p><b>Complete Construction:</b> The permittee shall complete construction of wastewater treatment system upgrades.</p>	06/30/2028
<p><b>Achieve Compliance:</b> The permittee shall achieve compliance with final BOD and Total Suspended Solids limitations.</p>	08/31/2028

### 4.3 Water Quality Based Effluent Limits (WQBELs) for Total Phosphorus

The permittee shall comply with the WQBELs for Phosphorus as specified. No later than 14 days following each compliance date, the permittee shall notify the Department in writing of its compliance or noncompliance. If a submittal is required, a timely submittal fulfills the notification requirement.

Required Action	Due Date
<p><b>Operational Evaluation Report:</b> The permittee shall prepare and submit to the Department for approval an operational evaluation report. The report shall include an evaluation of collected effluent data, possible source reduction measures, operational improvements or other minor facility modifications that will optimize reductions in phosphorus discharges from the treatment plant during the period prior to complying with final phosphorus WQBELs and, where possible, enable compliance with final phosphorus WQBELs by March 31, 2027. The report shall provide a plan and schedule for implementation of the measures, improvements, and modifications as soon as possible, but not later than March 31, 2027 and state whether the measures, improvements, and modifications will enable compliance with final phosphorus WQBELs. Regardless of whether they are expected to result in compliance, the permittee shall implement the measures, improvements, and modifications in accordance with the plan and schedule specified in the operational evaluation report.</p>	03/31/2025

<p>If the operational evaluation report concludes that the facility can achieve final phosphorus WQBELs using the existing treatment system with only source reduction measures, operational improvements, and minor facility modifications, the permittee shall comply with the final phosphorus WQBEL by March 31, 2027 and is not required to comply with the milestones identified below for years 3 through 9 of this compliance schedule ('Preliminary Compliance Alternatives Plan', 'Final Compliance Alternatives Plan', 'Final Plans and Specifications', 'Treatment Plant Upgrade to Meet WQBELs', 'Complete Construction', 'Achieve Compliance').</p> <p><b>STUDY OF FEASIBLE ALTERNATIVES</b> - If the Operational Evaluation Report concludes that the permittee cannot achieve final phosphorus WQBELs with source reduction measures, operational improvements and other minor facility modifications, the permittee shall initiate a study of feasible alternatives for meeting final phosphorus WQBELs and comply with the remaining required actions of this schedule of compliance. If the Department disagrees with the conclusion of the report, and determines that the permittee can achieve final phosphorus WQBELs using the existing treatment system with only source reduction measures, operational improvements, and minor facility modifications, the Department may reopen and modify the permit to include an implementation schedule for achieving the final phosphorus WQBELs sooner than March 31, 2033].</p>	
<p><b>Compliance Alternatives, Source Reduction, Improvements and Modifications Status:</b> The permittee shall submit a 'Compliance Alternatives, Source Reduction, Operational Improvements and Minor Facility Modification' status report to the Department. The report shall provide an update on the permittee's: (1) progress implementing source reduction measures, operational improvements, and minor facility modifications to optimize reductions in phosphorus discharges and, to the extent that such measures, improvements, and modifications will not enable compliance with the WQBELs, (2) status evaluating feasible alternatives for meeting phosphorus WQBELs.</p>	03/31/2026
<p><b>Preliminary Compliance Alternatives Plan:</b> The permittee shall submit a preliminary compliance alternatives plan to the Department.</p> <p>If the plan concludes upgrading of the permittee's wastewater treatment facility is necessary to achieve final phosphorus WQBELs, the submittal shall include a preliminary engineering design report.</p> <p>If water quality trading will be undertaken, the plan must state that trading will be pursued.</p>	03/31/2027
<p><b>Final Compliance Alternatives Plan:</b> The permittee shall submit a final compliance alternatives plan to the Department.</p> <p>If the plan concludes upgrading of the permittee's wastewater treatment is necessary to meet final phosphorus WQBELs, the submittal shall include a final engineering design report addressing the treatment plant upgrades, and a facility plan if required pursuant to ch. NR 110, Wis. Adm. Code.</p> <p>If the plan concludes water quality trading will be used, the submittal shall identify potential trading partners.</p> <p>Note: See 'Alternative Approaches to Phosphorus WQBEL Compliance' in the Surface Water section of this permit.</p>	03/31/2028
<p><b>Progress Report on Plans &amp; Specifications:</b> Submit progress report regarding the progress of preparing final plans and specifications. Note: See 'Alternative Approaches to Phosphorus WQBEL Compliance' in the Surface Water section of this permit.</p>	03/31/2029
<p><b>Final Plans and Specifications:</b> Unless the permit has been modified, revoked and reissued, or reissued to include Water Quality Trading measures or to include a revised schedule based on factors in s. NR 217.17, Wis. Adm. Code, the permittee shall submit final construction plans to the Department for approval pursuant to s. 281.41, Stats., specifying treatment plant upgrades that must</p>	03/31/2030

<p>be constructed to achieve compliance with final phosphorus WQBELs, and a schedule for completing construction of the upgrades by the complete construction date specified below. (Note: Permit modification, revocation and reissuance, and reissuance are subject to s. 283.53(2), Stats.)</p> <p>Note: See 'Alternative Approaches to Phosphorus WQBEL Compliance' in the Surface Water section of this permit.</p>	
<p><b>Treatment Plant Upgrade to Meet WQBELs:</b> The permittee shall initiate construction of the upgrades. The permittee shall obtain approval of the final construction plans and schedule from the Department pursuant to s. 281.41, Stats. Upon approval of the final construction plans and schedule by the Department pursuant to s. 281.41, Stats., the permittee shall construct the treatment plant upgrades in accordance with the approved plans and specifications. Note: See 'Alternative Approaches to Phosphorus WQBEL Compliance' in the Surface Water section of this permit.</p>	06/30/2030
<p><b>Construction Upgrade Progress Report #1:</b> The permittee shall submit a progress report on construction upgrades. Note: See 'Alternative Approaches to Phosphorus WQBEL Compliance' in the Surface Water section of this permit.</p>	06/30/2031
<p><b>Construction Upgrade Progress Report #2:</b> The permittee shall submit a progress report on construction upgrades. Note: See 'Alternative Approaches to Phosphorus WQBEL Compliance' in the Surface Water section of this permit.</p>	03/31/2032
<p><b>Complete Construction:</b> The permittee shall complete construction of wastewater treatment system upgrades. Note: See 'Alternative Approaches to Phosphorus WQBEL Compliance' in the Surface Water section of this permit.</p>	02/28/2033
<p><b>Achieve Compliance:</b> The permittee shall achieve compliance with final phosphorus WQBELs. Note: See 'Alternative Approaches to Phosphorus WQBEL Compliance' in the Surface Water section of this permit.</p>	03/31/2033

#### 4.4 Sludge Management Plan

A management plan is required for the land application system.

Required Action	Due Date
<p><b>Land Application Management Plan Submittal:</b> The permittee shall submit a management plan for approval if removal of sludge will occur during this permit term. The plan shall demonstrate compliance with ch. NR 204, Wis. Adm. Code and at minimum address 1) How and where is sludge sampled; 2) Available sludge storage details and location(s); 3) How will the sludge be removed with details on volume, characterization and how will the treatment plant continue to function during the drawdown; 4) Describe the type of transportation and spreading vehicles and loading and unloading practices; 5) Identify approved land application sites, apply for needed sites, site limitations, total acres needed and vegetative cover management; 6) Specify record keeping procedures including site loading; 7) Address contingency plans for adverse weather and odor/nuisance abatement; and 8) Include any other pertinent information such as other disposal options that may be used or specifications of any pretreatment processes</p> <p>Once approved, all sludge management activities shall be conducted in accordance with the plan. Any changes to the plan must be approved by the Department prior to implementing the changes. No desludging may occur unless approval from the Department is obtained. Daily logs shall be kept that record where the sludge has been disposed.</p>	

## 5 Standard Requirements

**NR 205, Wisconsin Administrative Code:** The conditions in ss. NR 205.07(1) and NR 205.07(2), Wis. Adm. Code, are included by reference in this permit. The permittee shall comply with all of these requirements. Some of these requirements are outlined in the Standard Requirements section of this permit. Requirements not specifically outlined in the Standard Requirement section of this permit can be found in ss. NR 205.07(1) and NR 205.07(2).

### 5.1 Reporting and Monitoring Requirements

#### 5.1.1 Monitoring Results

Monitoring results obtained during the previous month shall be summarized and reported on a Department Wastewater Discharge Monitoring Report. The report may require reporting of any or all of the information specified below under 'Recording of Results'. This report is to be returned to the Department no later than the date indicated on the form. A copy of the Wastewater Discharge Monitoring Report Form or an electronic file of the report shall be retained by the permittee.

Monitoring results shall be reported on an electronic discharge monitoring report (eDMR). The eDMR shall be certified electronically by a responsible executive or municipal officer, manager, partner or proprietor as specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner or proprietor that has been delegated signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The 'eReport Certify' page certifies that the electronic report form is true, accurate and complete.

If the permittee monitors any pollutant more frequently than required by this permit, the results of such monitoring shall be included on the Wastewater Discharge Monitoring Report.

The permittee shall comply with all limits for each parameter regardless of monitoring frequency. For example, monthly, weekly, and/or daily limits shall be met even with monthly monitoring. The permittee may monitor more frequently than required for any parameter.

#### 5.1.2 Sampling and Testing Procedures

Sampling and laboratory testing procedures shall be performed in accordance with Chapters NR 218 and NR 219, Wis. Adm. Code and shall be performed by a laboratory certified or registered in accordance with the requirements of ch. NR 149, Wis. Adm. Code. Groundwater sample collection and analysis shall be performed in accordance with ch. NR 140, Wis. Adm. Code. The analytical methodologies used shall enable the laboratory to quantitate all substances for which monitoring is required at levels below the effluent limitation. If the required level cannot be met by any of the methods available in NR 219, Wis. Adm. Code, then the method with the lowest limit of detection shall be selected. Additional test procedures may be specified in this permit.

#### 5.1.3 Recording of Results

The permittee shall maintain records which provide the following information for each effluent measurement or sample taken:

- the date, exact place, method and time of sampling or measurements;
- the individual who performed the sampling or measurements;
- the date the analysis was performed;
- the individual who performed the analysis;
- the analytical techniques or methods used; and
- the results of the analysis.

#### 5.1.4 Reporting of Monitoring Results

The permittee shall use the following conventions when reporting effluent monitoring results:

- Pollutant concentrations less than the limit of detection shall be reported as < (less than) the value of the limit of detection. For example, if a substance is not detected at a detection limit of 0.1 mg/L, report the pollutant concentration as < 0.1 mg/L.
- Pollutant concentrations equal to or greater than the limit of detection, but less than the limit of quantitation, shall be reported and the limit of quantitation shall be specified.
- For purposes of calculating NR 101 fees, the 2 mg/l lower reporting limits for BOD5 and Total Suspended Solids shall be considered to be limits of quantitation
- For the purposes of reporting a calculated result, average or a mass discharge value, the permittee may substitute a “0” (zero) for any pollutant concentration that is less than the limit of detection. However, if the effluent limitation is less than the limit of detection, the department may substitute a value other than zero for results less than the limit of detection, after considering the number of monitoring results that are greater than the limit of detection and if warranted when applying appropriate statistical techniques.
- If no discharge occurs through an outfall, flow related parameters (e.g. flow rate, hydraulic application rate, volume, etc.) should be reported as “0” (zero) at the required sample frequency specified for the outfall. For example: if the sample frequency is daily, “0” would be reported for any day during the month that no discharge occurred.

### **5.1.5 Compliance Maintenance Annual Reports**

Compliance Maintenance Annual Reports (CMAR) shall be completed using information obtained over each calendar year regarding the wastewater conveyance and treatment system. The CMAR shall be submitted and certified by the permittee in accordance with ch. NR 208, Wis. Adm. Code, by June 30, each year on an electronic report form provided by the Department.

In the case of a publicly owned treatment works, a resolution shall be passed by the governing body and submitted as part of the CMAR, verifying its review of the report and providing responses as required. Private owners of wastewater treatment works are not required to pass a resolution; but they must provide an Owner Statement and responses as required, as part of the CMAR submittal.

The CMAR shall be certified electronically by a responsible executive or municipal officer, manager, partner or proprietor as specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner or proprietor that has been delegated signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The certification verifies that the electronic report is true, accurate and complete.

### **5.1.6 Records Retention**

The permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings or electronic data records for continuous monitoring instrumentation, copies of all reports required by the permit, and records of all data used to complete the application for the permit for a period of at least 3 years from the date of the sample, measurement, report or application. All pertinent sludge information, including permit application information and other documents specified in this permit or s. NR 204.06(9), Wis. Adm. Code shall be retained for a minimum of 5 years.

### **5.1.7 Other Information**

Where the permittee becomes aware that it failed to submit any relevant facts in a permit application or submitted incorrect information in a permit application or in any report to the Department, it shall promptly submit such facts or correct information to the Department.

### **5.1.8 Reporting Requirements – Alterations or Additions**

The permittee shall give notice to the Department as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is only required when:

- The alteration or addition to the permitted facility may meet one of the criteria for determining whether a facility is a new source.
- The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification requirement applies to pollutants which are not subject to effluent limitations in the existing permit.
- The alteration or addition results in a significant change in the permittee's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use of disposal sites not reported during the permit application process nor reported pursuant to an approved land application plan. Additional sites may not be used for the land application of sludge until department approval is received.

## 5.2 System Operating Requirements

### 5.2.1 Noncompliance Reporting

Sanitary sewer overflows and sewage treatment facility overflows shall be reported according to the 'Sanitary Sewer Overflows and Sewage Treatment Facility Overflows' section of this permit.

The permittee shall report the following types of noncompliance by a telephone call to the Department's regional office within 24 hours after becoming aware of the noncompliance:

- any noncompliance which may endanger health or the environment;
- any violation of an effluent limitation resulting from a bypass;
- any violation of an effluent limitation resulting from an upset; and
- any violation of a maximum discharge limitation for any of the pollutants listed by the Department in the permit, either for effluent or sludge.

A written report describing the noncompliance shall also be submitted to the Department's regional office within 5 days after the permittee becomes aware of the noncompliance. On a case-by-case basis, the Department may waive the requirement for submittal of a written report within 5 days and instruct the permittee to submit the written report with the next regularly scheduled monitoring report. In either case, the written report shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times; the steps taken or planned to reduce, eliminate and prevent reoccurrence of the noncompliance; and if the noncompliance has not been corrected, the length of time it is expected to continue.

A scheduled bypass approved by the Department under the 'Scheduled Bypass' section of this permit shall not be subject to the reporting required under this section.

**NOTE:** Section 292.11(2)(a), Wisconsin Statutes, requires any person who possesses or controls a hazardous substance or who causes the discharge of a hazardous substance to notify the Department of Natural Resources immediately of any discharge not authorized by the permit. **The discharge of a hazardous substance that is not authorized by this permit or that violates this permit may be a hazardous substance spill. To report a hazardous substance spill, call DNR's 24-hour HOTLINE at 1-800-943-0003.**

### 5.2.2 Flow Meters

Flow meters shall be calibrated annually, as per s. NR 218.06, Wis. Adm. Code.

### 5.2.3 Raw Grit and Screenings

All raw grit and screenings shall be disposed of at a properly licensed solid waste facility or picked up by a licensed waste hauler. If the facility or hauler are located in Wisconsin, then they shall be licensed under chs. NR 500-555, Wis. Adm. Code.

### 5.2.4 Sludge Management



All sludge management activities shall be conducted in compliance with ch. NR 204 "Domestic Sewage Sludge Management", Wis. Adm. Code.

### **5.2.5 Prohibited Wastes**

Under no circumstances may the introduction of wastes prohibited by s. NR 211.10, Wis. Adm. Code, be allowed into the waste treatment system. Prohibited wastes include those:

- which create a fire or explosion hazard in the treatment work;
- which will cause corrosive structural damage to the treatment work;
- solid or viscous substances in amounts which cause obstructions to the flow in sewers or interference with the proper operation of the treatment work;
- wastewaters at a flow rate or pollutant loading which are excessive over relatively short time periods so as to cause a loss of treatment efficiency; and
- changes in discharge volume or composition from contributing industries which overload the treatment works or cause a loss of treatment efficiency.

### **5.2.6 Bypass**

This condition applies only to bypassing at a sewage treatment facility that is not a scheduled bypass, approved blending as a specific condition of this permit, a sewage treatment facility overflow or a controlled diversion as provided in the sections titled 'Scheduled Bypass', 'Blending' (if approved), 'SSO's and Sewage Treatment Facility Overflows' and 'Controlled Diversions' of this permit. Any other bypass at the sewage treatment facility is prohibited and the Department may take enforcement action against a permittee for such occurrences under s. 283.89, Wis. Stats. The Department may approve a bypass if the permittee demonstrates all the following conditions apply:

- The bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
- There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities or adequate back-up equipment, retention of untreated wastes, reduction of inflow and infiltration, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventative maintenance. When evaluating feasibility of alternatives, the department may consider factors such as technical achievability, costs and affordability of implementation and risks to public health, the environment and, where the permittee is a municipality, the welfare of the community served; and
- The bypass was reported in accordance with the Noncompliance Reporting section of this permit.

### **5.2.7 Scheduled Bypass**

Whenever the permittee anticipates the need to bypass for purposes of efficient operations and maintenance and the permittee may not meet the conditions for controlled diversions in the 'Controlled Diversions' section of this permit, the permittee shall obtain prior written approval from the Department for the scheduled bypass. A permittee's written request for Department approval of a scheduled bypass shall demonstrate that the conditions for bypassing specified in the above section titled 'Bypass' are met and include the proposed date and reason for the bypass, estimated volume and duration of the bypass, alternatives to bypassing and measures to mitigate environmental harm caused by the bypass. The department may require the permittee to provide public notification for a scheduled bypass if it is determined there is significant public interest in the proposed action and may recommend mitigation measures to minimize the impact of such bypass.

### **5.2.8 Controlled Diversions**

Controlled diversions are allowed only when necessary for essential maintenance to assure efficient operation. Sewage treatment facilities that have multiple treatment units to treat variable or seasonal loading conditions may shut down redundant treatment units when necessary for efficient operation. The following requirements shall be met during controlled diversions:

- Effluent from the sewage treatment facility shall meet the effluent limitations established in the permit. Wastewater that is diverted around a treatment unit or treatment process during a controlled diversion shall be recombined with wastewater that is not diverted prior to the effluent sampling location and prior to effluent discharge;
- A controlled diversion does not include blending as defined in s. NR 210.03(2e), Wis. Adm. Code, and as may only be approved under s. NR 210.12. A controlled diversion may not occur during periods of excessive flow or other abnormal wastewater characteristics;
- A controlled diversion may not result in a wastewater treatment facility overflow; and
- All instances of controlled diversions shall be documented in sewage treatment facility records and such records shall be available to the department on request.

### **5.2.9 Proper Operation and Maintenance**

The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance includes effective performance, adequate funding, adequate operator staffing and training as required in ch. NR 114, Wis. Adm. Code, and adequate laboratory and process controls, including appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems only when necessary to achieve compliance with the conditions of the permit.

### **5.2.10 Operator Certification**

The wastewater treatment facility shall be under the direct supervision of a state certified operator. In accordance with s. NR 114.53, Wis. Adm. Code, every WPDES permitted treatment plant shall have a designated operator-in-charge holding a current and valid certificate. The designated operator-in-charge shall be certified at the level and in all subclasses of the treatment plant, except laboratory. Treatment plant owners shall notify the department of any changes in the operator-in-charge within 30 days. Note that s. NR 114.52(22), Wis. Adm. Code, lists types of facilities that are excluded from operator certification requirements (i.e. private sewage systems, pretreatment facilities discharging to public sewers, industrial wastewater treatment that consists solely of land disposal, agricultural digesters and concentrated aquatic production facilities with no biological treatment).

## **5.3 Sewage Collection Systems**

### **5.3.1 Sanitary Sewage Overflows and Sewage Treatment Facility Overflows**

#### **5.3.1.1 Overflows Prohibited**

Any overflow or discharge of wastewater from the sewage collection system or at the sewage treatment facility, other than from permitted outfalls, is prohibited. The permittee shall provide information on whether any of the following conditions existed when an overflow occurred:

- The sanitary sewer overflow or sewage treatment facility overflow was unavoidable to prevent loss of life, personal injury or severe property damage;
- There were no feasible alternatives to the sanitary sewer overflow or sewage treatment facility overflow such as the use of auxiliary treatment facilities or adequate back-up equipment, retention of untreated wastes, reduction of inflow and infiltration, or preventative maintenance activities;
- The sanitary sewer overflow or the sewage treatment facility overflow was caused by unusual or severe weather related conditions such as large or successive precipitation events, snowmelt, saturated soil

conditions, or severe weather occurring in the area served by the sewage collection system or sewage treatment facility; and

- The sanitary sewer overflow or the sewage treatment facility overflow was unintentional, temporary, and caused by an accident or other factors beyond the reasonable control of the permittee.

### 5.3.1.2 Permittee Response to Overflows

Whenever a sanitary sewer overflow or sewage treatment facility overflow occurs, the permittee shall take all feasible steps to control or limit the volume of untreated or partially treated wastewater discharged, and terminate the discharge as soon as practicable. Remedial actions, including those in NR 210.21 (3), Wis. Adm. Code, shall be implemented consistent with an emergency response plan developed under the CMOM program.

### 5.3.1.3 Permittee Reporting

Permittees shall report all sanitary sewer overflows and sewage treatment overflows as follows:

- The permittee shall notify the department by telephone, fax or email as soon as practicable, but no later than 24 hours from the time the permittee becomes aware of the overflow;
- The permittee shall, no later than five days from the time the permittee becomes aware of the overflow, provide to the department the information identified in this paragraph using department form number 3400-184. If an overflow lasts for more than five days, an initial report shall be submitted within 5 days as required in this paragraph and an updated report submitted following cessation of the overflow. At a minimum, the following information shall be included in the report:
  - The date and location of the overflow;
  - The surface water to which the discharge occurred, if any;
  - The duration of the overflow and an estimate of the volume of the overflow;
  - A description of the sewer system or treatment facility component from which the discharge occurred such as manhole, lift station, constructed overflow pipe, or crack or other opening in a pipe;
  - The estimated date and time when the overflow began and stopped or will be stopped;
  - The cause or suspected cause of the overflow including, if appropriate, precipitation, runoff conditions, areas of flooding, soil moisture and other relevant information;
  - Steps taken or planned to reduce, eliminate and prevent reoccurrence of the overflow and a schedule of major milestones for those steps;
  - A description of the actual or potential for human exposure and contact with the wastewater from the overflow;
  - Steps taken or planned to mitigate the impacts of the overflow and a schedule of major milestones for those steps;
  - To the extent known at the time of reporting, the number and location of building backups caused by excessive flow or other hydraulic constraints in the sewage collection system that occurred concurrently with the sanitary sewer overflow and that were within the same area of the sewage collection system as the sanitary sewer overflow; and
  - The reason the overflow occurred or explanation of other contributing circumstances that resulted in the overflow event. This includes any information available including whether the overflow was unavoidable to prevent loss of life, personal injury, or severe property damage and whether there were feasible alternatives to the overflow.

**NOTE:** A copy of form 3400-184 for reporting sanitary sewer overflows and sewage treatment facility overflows may be obtained from the department or accessed on the department's web site at <http://dnr.wi.gov/topic/wastewater/SSOreport.html>. As indicated on the form, additional information may be submitted to supplement the information required by the form.

- The permittee shall identify each specific location and each day on which a sanitary sewer overflow or sewage treatment facility overflow occurs as a discrete sanitary sewer overflow or sewage treatment facility overflow occurrence. An occurrence may be more than one day if the circumstances causing the sanitary sewer overflow or sewage treatment facility overflow results in a discharge duration of greater than 24 hours. If there is a stop and restart of the overflow at the same location within 24 hours and the overflow is caused by the same circumstance, it may be reported as one occurrence. Sanitary sewer overflow occurrences at a specific location that are separated by more than 24 hours shall be reported as separate occurrences; and
- A permittee that is required to submit wastewater discharge monitoring reports under NR 205.07 (1) (r) shall also report all sanitary sewer overflows and sewage treatment facility overflows on that report.

#### **5.3.1.4 Public Notification**

The permittee shall notify the public of any sanitary sewer and sewage treatment facility overflows consistent with its emergency response plan required under the CMOM (Capacity, Management, Operation and Maintenance) section of this permit and s. NR 210.23 (4) (f), Wis. Adm. Code. Such public notification shall occur promptly following any overflow event using the most effective and efficient communications available in the community. At minimum, a daily newspaper of general circulation in the county(s) and municipality whose waters may be affected by the overflow shall be notified by written or electronic communication.

#### **5.3.2 Capacity, Management, Operation and Maintenance (CMOM) Program**

- The permittee shall have written documentation of the Capacity, Management, Operation and Maintenance (CMOM) program components in accordance with s. NR 210.23(4), Wis. Adm. Code. Such documentation shall be available for Department review upon request. The Department may request that the permittee provide this documentation or prepare a summary of the permittee's CMOM program at the time of application for reissuance of the WPDES permit.
- The permittee shall implement a CMOM program in accordance with s. NR 210.23, Wis. Adm. Code.
- The permittee shall at least annually conduct a self-audit of activities conducted under the permittee's CMOM program to ensure CMOM components are being implemented as necessary to meet the general standards of s. NR 210.23(3), Wis. Adm. Code.

#### **5.3.3 Sewer Cleaning Debris and Materials**

All debris and material removed from cleaning sanitary sewers shall be managed to prevent nuisances, run-off, ground infiltration or prohibited discharges.

- Debris and solid waste shall be dewatered, dried and then disposed of at a licensed solid waste facility.
- Liquid waste from the cleaning and dewatering operations shall be collected and disposed of at a permitted wastewater treatment facility.
- Combination waste including liquid waste along with debris and solid waste may be disposed of at a licensed solid waste facility or wastewater treatment facility willing to accept the waste.

### **5.4 Surface Water Requirements**

#### **5.4.1 Permittee-Determined Limit of Quantitation Incorporated into this Permit**

For pollutants with water quality-based effluent limits below the Limit of Quantitation (LOQ) in this permit, the LOQ calculated by the permittee and reported on the Discharge Monitoring Reports (DMRs) is incorporated by reference into this permit. The LOQ shall be reported on the DMRs, shall be the lowest quantifiable level practicable, and shall be no greater than the minimum level (ML) specified in or approved under 40 CFR Part 136 for the pollutant at the time this permit was issued, unless this permit specifies a higher LOQ.

### 5.4.2 Appropriate Formulas for Effluent Calculations

The permittee shall use the following formulas for calculating effluent results to determine compliance with average concentration limits and mass limits and total load limits:

**Weekly/Monthly/Six-Month/Annual Average Concentration** = the sum of all daily results for that week/month/six-month/year, divided by the number of results during that time period. [Note: When a six-month average effluent limit is specified for Total Phosphorus the applicable periods are May through October and November through April.]

**Weekly Average Mass Discharge (lbs/day):** Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the week.

**Monthly Average Mass Discharge (lbs/day):** Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the month.

**Six-Month Average Mass Discharge (lbs/day):** Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the six-month period. [Note: When a six-month average effluent limit is specified for Total Phosphorus the applicable periods are May through October and November through April.]

**Annual Average Mass Discharge (lbs/day):** Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the entire year.

**Total Monthly Discharge:** = monthly average concentration (mg/L) x total flow for the month (MG/month) x 8.34.

**Total Annual Discharge:** = sum of total monthly discharges for the calendar year.

**12-Month Rolling Sum of Total Monthly Discharge:** = the sum of the most recent 12 consecutive months of Total Monthly Discharges.

### 5.4.3 Visible Foam or Floating Solids

There shall be no discharge of floating solids or visible foam in other than trace amounts.

### 5.4.4 Surface Water Uses and Criteria

In accordance with NR 102.04, Wis. Adm. Code, surface water uses and criteria are established to govern water management decisions. Practices attributable to municipal, industrial, commercial, domestic, agricultural, land development or other activities shall be controlled so that all surface waters including the mixing zone meet the following conditions at all times and under all flow and water level conditions:

- a) Substances that will cause objectionable deposits on the shore or in the bed of a body of water, shall not be present in such amounts as to interfere with public rights in waters of the state.
- b) Floating or submerged debris, oil, scum or other material shall not be present in such amounts as to interfere with public rights in waters of the state.
- c) Materials producing color, odor, taste or unsightliness shall not be present in such amounts as to interfere with public rights in waters of the state.
- d) Substances in concentrations or in combinations which are toxic or harmful to humans shall not be present in amounts found to be of public health significance, nor shall substances be present in amounts which are acutely harmful to animal, plant or aquatic life.

### 5.4.5 Percent Removal

During any 30 consecutive days, the average effluent concentrations of BOD<sub>5</sub> and of total suspended solids shall not exceed 15% of the average influent concentrations, respectively. This requirement does not apply to removal of total suspended solids if the permittee operates a lagoon system and has received a variance for suspended solids granted under NR 210.07(2), Wis. Adm. Code.

#### **5.4.6 PFOS and PFOA Requirements**

The laboratory performing the analysis on any samples shall be certified for the applicable PFAS compounds in the aqueous matrix by the Wisconsin Laboratory Certification Program established under s. 299.11, Wis. Stats., in accordance with s. NR 149.41, Wis. Adm. Code. If the EPA Office of Water publishes a 1600 series isotope dilution method for the analysis of PFAS in wastewater, the department recommends the use of the EPA method.

The Department may reject any sample results if results are produced by a laboratory that is not in compliance with certification requirements under ch. NR 149, Wis. Adm. Code.

### **5.5 Land Application Requirements**

#### **5.5.1 Sludge Management Program Standards And Requirements Based Upon Federally Promulgated Regulations**

In the event that new federal sludge standards or regulations are promulgated, the permittee shall comply with the new sludge requirements by the dates established in the regulations, if required by federal law, even if the permit has not yet been modified to incorporate the new federal regulations.

#### **5.5.2 General Sludge Management Information**

The General Sludge Management Form 3400-48 shall be completed and submitted prior to any significant sludge management changes.

#### **5.5.3 Sludge Samples**

All sludge samples shall be collected at a point and in a manner which will yield sample results which are representative of the sludge being tested, and collected at the time which is appropriate for the specific test.

#### **5.5.4 Land Application Characteristic Report**

Each report shall consist of a Characteristic Form 3400-49 and Lab Report. The Characteristic Report Form 3400-49 shall be submitted electronically by January 31 following each year of analysis.

Following submittal of the electronic Characteristic Report Form 3400-49, this form shall be certified electronically via the 'eReport Certify' page by a responsible executive or municipal officer, manager, partner or proprietor as specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner or proprietor that has been delegated signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The 'eReport Certify' page certifies that the electronic report is true, accurate and complete. The Lab Report must be sent directly to the facility's DNR sludge representative or basin engineer unless approval for not submitting the lab reports has been given.

The permittee shall use the following convention when reporting sludge monitoring results: Pollutant concentrations less than the limit of detection shall be reported as < (less than) the value of the limit of detection. For example, if a substance is not detected at a detection limit of 1.0 mg/kg, report the pollutant concentration as < 1.0 mg/kg .

All results shall be reported on a dry weight basis.

#### **5.5.5 Calculation of Water Extractable Phosphorus**

When sludge analysis for Water Extractable Phosphorus is required by this permit, the permittee shall use the following formula to calculate and report Water Extractable Phosphorus:

Water Extractable Phosphorus (% of Total P) =

$$[\text{Water Extractable Phosphorus (mg/kg, dry wt)} \div \text{Total Phosphorus (mg/kg, dry wt)}] \times 100$$

#### **5.5.6 Annual Land Application Report**

Land Application Report Form 3400-55 shall be submitted electronically by January 31, each year whether or not non-exceptional quality sludge is land applied. Non-exceptional quality sludge is defined in s. NR 204.07(4), Wis. Adm. Code. Following submittal of the electronic Annual Land Application Report Form 3400-55, this form shall be certified electronically via the ‘eReport Certify’ page by a responsible executive or municipal officer, manager, partner or proprietor as specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner or proprietor that has been delegated signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The ‘eReport Certify’ page certifies that the electronic report form is true, accurate and complete.

### **5.5.7 Other Methods of Disposal or Distribution Report**

The permittee shall submit electronically the Other Methods of Disposal or Distribution Report Form 3400-52 by January 31, each year whether or not sludge is hauled, landfilled, incinerated, or exceptional quality sludge is distributed or land applied. Following submittal of the electronic Report Form 3400-52, this form shall be certified electronically via the ‘eReport Certify’ page by a responsible executive or municipal officer, manager, partner or proprietor as specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner or proprietor that has been delegated signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The ‘eReport Certify’ page certifies that the electronic report form is true, accurate and complete.

### **5.5.8 Approval to Land Apply**

Bulk non-exceptional quality sludge as defined in s. NR 204.07(4), Wis. Adm. Code, may not be applied to land without a written approval letter or Form 3400-122 from the Department unless the Permittee has obtained permission from the Department to self approve sites in accordance with s. NR 204.06 (6), Wis. Adm. Code. Analysis of sludge characteristics is required prior to land application. Application on frozen or snow covered ground is restricted to the extent specified in s. NR 204.07(3) (1), Wis. Adm. Code.

### **5.5.9 Soil Analysis Requirements**

Each site requested for approval for land application must have the soil tested prior to use. Each approved site used for land application must subsequently be soil tested such that there is at least one valid soil test in the four years prior to land application. All soil sampling and submittal of information to the testing laboratory shall be done in accordance with UW Extension Bulletin A-2100. The testing shall be done by the UW Soils Lab in Madison or Marshfield, WI or at a lab approved by UW. The test results including the crop recommendations shall be submitted to the DNR contact listed for this permit, as they are available. Application rates shall be determined based on the crop nitrogen recommendations and with consideration for other sources of nitrogen applied to the site.

### **5.5.10 Land Application Site Evaluation**

For non-exceptional quality sludge, as defined in s. NR 204.07(4), Wis. Adm. Code, a Land Application Site Request Form 3400-053 shall be submitted to the Department for the proposed land application site. The Department will evaluate the proposed site for acceptability and will either approve or deny use of the proposed site. The permittee may obtain permission to approve their own sites in accordance with s. NR 204.06(6), Wis. Adm. Code.

## 6 Summary of Reports Due

FOR INFORMATIONAL PURPOSES ONLY

<b>Description</b>	<b>Date</b>	<b>Page</b>
PFOS/PFOA Minimization Plan Determination of Need -Report on Effluent Discharge	March 31, 2025	15
PFOS/PFOA Minimization Plan Determination of Need -Report on Effluent Discharge and Evaluation of Need	March 31, 2026	15
Effluent Limitations for BOD5 and Total Suspended Solids -Operational Evaluation Report	March 31, 2025	15
Effluent Limitations for BOD5 and Total Suspended Solids -Submit Facility Plan	March 31, 2026	16
Effluent Limitations for BOD5 and Total Suspended Solids -Final Plans and Specifications	March 31, 2027	16
Effluent Limitations for BOD5 and Total Suspended Solids -Treatment Plant Upgrade to Meet Limitations	March 31, 2028	16
Effluent Limitations for BOD5 and Total Suspended Solids -Complete Construction	June 30, 2028	16
Effluent Limitations for BOD5 and Total Suspended Solids -Achieve Compliance	August 31, 2028	16
Water Quality Based Effluent Limits (WQBELs) for Total Phosphorus - Operational Evaluation Report	March 31, 2025	16
Water Quality Based Effluent Limits (WQBELs) for Total Phosphorus - Compliance Alternatives, Source Reduction, Improvements and Modifications Status	March 31, 2026	17
Water Quality Based Effluent Limits (WQBELs) for Total Phosphorus - Preliminary Compliance Alternatives Plan	March 31, 2027	17
Water Quality Based Effluent Limits (WQBELs) for Total Phosphorus - Final Compliance Alternatives Plan	March 31, 2028	17
Water Quality Based Effluent Limits (WQBELs) for Total Phosphorus - Progress Report on Plans & Specifications	March 31, 2029	17
Water Quality Based Effluent Limits (WQBELs) for Total Phosphorus - Final Plans and Specifications	March 31, 2030	18
Water Quality Based Effluent Limits (WQBELs) for Total Phosphorus - Treatment Plant Upgrade to Meet WQBELs	June 30, 2030	18
Water Quality Based Effluent Limits (WQBELs) for Total Phosphorus - Construction Upgrade Progress Report #1	June 30, 2031	18
Water Quality Based Effluent Limits (WQBELs) for Total Phosphorus - Construction Upgrade Progress Report #2	March 31, 2032	18
Water Quality Based Effluent Limits (WQBELs) for Total Phosphorus - Complete Construction	February 28, 2033	18
Water Quality Based Effluent Limits (WQBELs) for Total Phosphorus -	March 31, 2033	18



Achieve Compliance		
Sludge Management Plan -Land Application Management Plan Submittal	See Permit	18
Compliance Maintenance Annual Reports (CMAR)	by June 30, each year	20
General Sludge Management Form 3400-48	prior to any significant sludge management changes	27
Characteristic Form 3400-49 and Lab Report	by January 31 following each year of analysis	27
Land Application Report Form 3400-55	by January 31, each year whether or not non-exceptional quality sludge is land applied	28
Other Methods of Disposal or Distribution Report Form 3400-52	by January 31, each year whether or not sludge is hauled, landfilled, incinerated, or exceptional quality sludge is distributed or land applied	28
Wastewater Discharge Monitoring Report	no later than the date indicated on the form	19

Report forms shall be submitted electronically in accordance with the reporting requirements herein. Any facility plans or plans and specifications for municipal, industrial, industrial pretreatment and non industrial wastewater systems shall be submitted to the Bureau of Water Quality, P.O. Box 7921, Madison, WI 53707-7921. All other submittals required by this permit shall be submitted to:  
Northern Region - Spooner, 810 W. Maple St, Spooner, WI 54801-1255