

STATE OF WISCONSIN DEPARTMENT OF NATURAL RESOURCES  
PUBLIC NOTICE OF INTENT TO REISSUE A WISCONSIN POLLUTANT DISCHARGE ELIMINATION  
SYSTEM (WPDES) PERMIT No.WI-0020516-09-0

Permittee: Village of Kendall, PO Box 216, Kendall, WI 54638-8622

Facility Where Discharge Occurs: Kendall Wastewater Treatment Facility, 208 East South Railroad St., Kendall, WI

Receiving Water and Location: Baraboo River in the Seymour Creek and Upper Baraboo River Watershed of the Lower Wisconsin River Basin in Monroe County

Brief Facility Description and Summary of Proposed Changes: The Kendall Wastewater Treatment Plant is a conventional package plant with aeration and re-aeration basins, a center clarifier, and aerobic sludge treatment. The facility treats domestic waste from the Village of Kendall. The annual average design flow is 0.070 million gallons per day (MGD), and had an actual annual average flow of 0.056 MGD in 2012. Effluent is disinfected via chlorination (and is followed by dechlorination) prior to discharge to the Baraboo River. Sludge generated at the facility is aerobically digested and hauled to the Elroy WWTF. No operational changes since the last permit term. Proposed monitoring changes since the last permit term include 1) removal of effluent copper limits and replaced with monitoring, 2) addition of effluent phosphorus limits and an associated compliance schedule, 3) effluent temperature monitoring in 2017, and 4) the removal of hardness monitoring.

Permit Drafter: Angela Parkhurst, DNR, WCR Headquarters, 1300 W. Clairemont Ave., Eau Claire, WI 54701, (715) 839-3836, [angela.parkhurst@wisconsin.gov](mailto:angela.parkhurst@wisconsin.gov)

Basin Engineer: Peter Pfefferkorn, DNR, 473 Griffith Avenue, Wisconsin Rapids, WI 54494, (715) 421-7868, [peter.pfefferkorn@wisconsin.gov](mailto:peter.pfefferkorn@wisconsin.gov)

The Department has tentatively decided that the above specified WPDES permit should be reissued.

Dissipative Cooling: The department may account for dissipative cooling of the permittee's treated domestic sewage effluent in determining the need for sub-lethal temperature limits pursuant to s. NR 106.59, Wis. Adm.Code. Based on the department's evaluation it has been determined that sub-lethal effluent limits for temperature are not necessary because the permittee's effluent thermal load is adequately dissipated. Comments on this determination are requested.

Persons wishing to comment on or object to the proposed permit action, or to request a public hearing, may write to the Department of Natural Resources at the permit drafter's address. All comments or suggestions received no later than 30 days after the publication date of this public notice will be considered along with other information on file in making a final decision regarding the permit. Anyone providing comments in response to this public notice will receive a notification of the Department's final decision when the permit is issued. Where designated as a reviewable surface water discharge permit, the U.S. Environmental Protection Agency is allowed up to 90 days to submit comments or objections regarding this permit determination. If no comments are received on the proposed permit from anyone, including U.S. EPA, the permit will be issued as proposed.

The Department may schedule a public informational hearing if requested by any person and shall schedule a public informational hearing if a petition requesting a hearing is received from 5 or more persons or if response to this notice indicates significant public interest pursuant to s. 283.49, Stats. Requests for a public informational hearing shall state the following: the name and address of the person(s) requesting the hearing; the interest in the proposed permit of the person(s) requesting the hearing; the reasons for the request; and the issues proposed to be considered at the hearing.

Information on file for this permit action, including the draft permit, fact sheet (if required), and permit application, may be inspected and copied at the permit drafter's or basin engineer's office, Monday through Friday (except holidays), between 9:00 a.m. and 3:30 p.m. Please call the permit drafter or basin engineer for directions to their office location, if necessary. Information on this permit action may also be obtained by calling the permit drafter at (715) 839-3836 or by writing to the Department. Reasonable costs (usually 20 cents per page) will be charged for copies of information in the file other than the public notice and fact sheet. Permit information is also available on the internet at: <http://dnr.wi.gov/topic/wastewater/PublicNotices.html>. Pursuant to the Americans with Disabilities Act, reasonable accommodation, including the provision of informational material in an alternative format, will be made to qualified individuals upon request.

PUBLISHING NEWSPAPERS: The Messenger, 229 Main Street, Elroy, WI 53929; The County Line, PO Box 7, Ontario, WI 54651-0007

Date Notice Issued: November 7, 2013